



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Alchemy Polymers, LLC
4508 Bibb Blvd
Suite B-5
Tucker, GA 30084, United States

Plant Location:

Tucker, GA, United States

Standards:

NSF/ANSI 61 Section 5

Certificate:

Issued: 08/25/2015
Expires: 12/31/2020

Material/Product:

Two Component, High Strength, High Density, Hydro insensitive Structural Polyurethane Foam

Contact Temperature:

23 ± 2 C

Models:

AP Lift 475 v. 3.0



Material Characteristics:

Minimum tank size (gallons): 5

Maximum tank surface area/volume ratio (sq in/L): 40.4

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 3 days

Mix ratio: 1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): No