



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Alchemy Spetec
4508 Bibb Blvd
Suite B-5
Tucker, GA 30084, United States

Plant Location:

Tucker, GA, United States

Standards:

NSF/ANSI 61 Section 5 - 2017

Certificate:

Issued: 09/19/2018

Material/Product:

Spetec PUR GT500 - Single Component, Low Viscosity, Flexible Hydrophilic Polyurethane Foam Injection Resin

Contact Temperature:

23 ± 2°C

Models:

Spetec PUR GT500



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum tank size (gallons): 10000

Maximum tank surface area/volume ratio (sq in/L): 2.6

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 24 hrs at 23 °C

Mix ratio: 2:1 by weight

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.