



## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

Alchemy Spetec  
4508 Bibb Blvd  
Suite B-5  
Tucker, GA 30084, United States

**Plant Location:**

Tucker, GA, United States

**Standards:**

NSF/ANSI 61 Section 5 - 2017

**Certificate:**

Issued: 06/19/2018

**Material/Product:**

Spetec PUR HighFoamer- Polyurethane Injection resin

**Contact Temperature:**

23 ± 2°C

**Models:**

Spetec PUR HighFoamer

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



## Material Characteristics:

Minimum tank size (gallons): 4000

Maximum tank surface area/volume ratio (sq in/L): 3.6

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hrs at  $23 \pm 2$  °C

Final cure time: 24 hrs at  $23 \pm 2$  °C

Mix ratio: 18:1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.